



**August 24, 2009**

**ADDENDUM NO. 1**

**Addendum to City of Bryan Request for Bid No. 09-153**

**“Cole St. and Johnson St. Sewer Improvements”  
City Job #411-D4-0909**

**The following changes and clarifications are hereby incorporated into the bid documents and specifications for this project.**

The joint of pressure rated pipe centered on the existing waterline (approximate station 0+23) will only be required if there is less than 9-ft of separation between the water and sewer line.

The correct grades for manhole #2 are labeled in the profile of sewer line “B”. The plan view and sewer line “A” profile should read FL IN (W) = 326.23.

The service line running to the main near manhole #3 shall connect into the manhole, not the main.

Manhole #4 is a 5-ft diameter inside drop manhole.

Manholes #5, 6, 7 & 8 shall be installed with the rim elevation 2.5 ft above grade.

In order to shorten the length of sewer line “C”, manhole #8 shall be installed along the existing sewer alignment as soon as grades allow, with a minimum of 1/10 ft fall through manhole.

Pier supports shall be 32” diameter and drilled to a minimum depth of 6-ft below existing grade. See standard detail S4-00.

**The deadline for questions has been extended to August 25<sup>th</sup> at 1:00 p.m.**

**END OF ADDENDUM**

Bidders are required to acknowledge receipt of addendums in the space provided in the bid documents. It is not necessary to submit copies of the addendums in the sealed bid submitted to the City of Bryan.